



EXCHANGER SIZE *BAFFLE SPACING	DIMENSIONS											
	A		B		C		D		N1		N2	
	inches	mm	inches	mm	inches	mm	inches	mm	inches	mm	inches	mm
WX-42-4*-1	28 1/2	724	16 1/2	419	9 1/2	241	27	686	2	51	2	51
WX-43-4*-1	40 1/2	1029	28 1/2	724	21 1/2	546	39	991	2	51	2	51
WX-44-4*-1	52 1/2	1334	40 1/2	1029	33 1/2	851	51	1295	2	51	2	51
WX-45-4*-1	64 1/2	1638	52 1/2	1334	45 1/2	1156	63	1600	2	51	2	51
WX-46-4*-1	76 1/2	1943	64 1/2	1638	57 1/2	1461	75	1905	2	51	2	51
WX-47-4*-1	88 1/2	2248	76 1/2	1943	69 1/2	1765	87	2210	2	51	2	51
WX-48-4*-1	100 1/2	2553	88 1/2	2248	81 1/2	2070	99	2515	2	51	2	51
WX-49-4*-1	112 1/2	2858	100 1/2	2553	93 1/2	2375	111	2819	2	51	2	51
WX-410-4*-1	124 1/2	3162	112 1/2	2858	105 1/2	2680	123	3124	2	51	2	51

NOZZLE SCHEDULE				
SERVICE	MARK	SHELL SIDE	MARK	TUBE SIDE
INLET	(N1)	AS PER TABLE	(N5)	1 (25) NPT
OUTLET	(N2)	AS PER TABLE	(N6)	1 (25) NPT
DRAIN	(N3)	1/2 (13) NPT	(N7)	1/2 (13) NPT
VENT	(N4)	3/4 (19) NPT		

NOTES: 1. SUPPORTS SUPPLIED ONLY IF SPECIFIED ON ORDER.  
 2. NOZZLE SIZES SHOWN ARE RECOMMENDED FOR MAXIMUM EXCHANGER LIFE.  
 3. FABRICATED TO ASME CODE SECTION VIII DIVISION 1 AND LATEST ADDENDA.  
 4. DRAWING IS NOT TO SCALE.  
 5. ALL DIMN'S ±1/8 (3) UNLESS OTHERWISE SHOWN.

DESIGN CONDITIONS				
	SHELL		TUBES	
DESIGN PRESSURE	150 PSIG	1034 KP <sub>a</sub>	150 PSIG	1034 KP <sub>a</sub>
DESIGN TEMPERATURE	375 °F	191 °C	375 °F	191 °C
MIN. DESIGN METAL TEMP.	35 °F	1.7 °C	35 °F	1.7 °C
HYDRO. TEST PRESSURE	225 PSIG	1551 KP <sub>a</sub>	300 PSIG	2068 KP <sub>a</sub>
CONTENTS	WATER		WATER	

CUSTOMER:  
 LOCATION:  
 ENGINEER:  
 ORDER No.:  
 PROJECT/JOB:  
 LOCATION:  
 TAG: (QUOTE # )

TITLE	A R M S T R O N G				NUMBER	REV.
G.A. 150 LB. WX SERIES HEAT EXCHANGERS	TORONTO - CANADA	MONTREAL - CANADA	BUFFALO - N. Y.	COLCHESTER - U.K.	WX-4-4-1(2)	
DATE: 12 / 01 / 94 BY: D.C.R.	TEL: (+16) 755-2291	TEL: (514) 421-2424	TEL: (716) 693-8813	TEL: (44) 120-657-9491		